

TOOLBOX TALKS


Energy Isolation (EI)

Isolation to Protect Multiple Persons

The isolator must Lock-Out, Tag-Out and Test-Out the PES.

Isolation Controller places control locks at each isolation point.

Isolation Controller places all control lock keys in a lock-out box and attaches personal lock.



Each Lock Holder must attach their own personal lock and tag to the lock-out box.

When work is completed:

The Isolation Controller must be the first person to place a lock and the last one to remove it.

DISCUSSION

Questions from staff

Comments by staff

Suggestions from staff

TOOLBOX TALK ATTENDANCE REGISTER

Date		Facilitator Name:	
Site/Department:		Facilitator Signature:	
Topic:			

The information in this document had been explained to me and I understand the content

Emp Name	Emp No	Signature	Emp Name	Emp No	Signature