


TOOLBOX TALKS

Energy Isolation (EI)

Isolation to Protect Multiple Persons

Communication

The Isolator shutting down and isolating OR starting up the PES must inform everyone who may be affected, in advance.



Handover Procedure

If maintenance activities go over shifts, the Isolation Controller going off-shift must:

- Ensure Lock Holders, also leaving the shift, remove their personal locks and leave the hazard area.
- Exchange their Lock-Out device at the hand-over and communicate with the Isolation Controller starting the new shift.
- The incoming Isolation Controller must ensure that all incoming Lock Holders add their lock.

DISCUSSION

Questions from staff

Comments by staff

Suggestions from staff

TOOLBOX TALK ATTENDANCE REGISTER

Date		Facilitator Name:	
Site/Department:		Facilitator Signature:	
Topic:			

The information in this document had been explained to me and I understand the content

Emp Name	Emp No	Signature	Emp Name	Emp No	Signature